



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX PRE 20.0044X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2020-06-11

Applicant: **LASER DIAGNOSTIC INSTRUMENTS AS**
Kopliiranna 49
Tallinn 11713
Estonia

Equipment: **Remote Optical Watcher**

Optional accessory:

Type of Protection: **Ex d**

Marking: Ex db IIC T6 Gb, T_{amb} -30°C to +60°C

Approved for issue on behalf of the IECEx
Certification Body:

Bjørn Spongsveen

Position:

Certification Manager, Ex-products

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DNV GL Presafe AS
Veritasveien 3
1363 Høvik
Norway





IECEx Certificate of Conformity

Certificate No.: **IECEx PRE 20.0044X**

Page 2 of 3

Date of issue: 2020-06-11

Issue No: 0

Manufacturer: **LASER DIAGNOSTIC INSTRUMENTS AS**
Kopliiranna 49
Tallinn 11713
Estonia

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NO/PRE/ExTR20.0023/00](#)

Quality Assessment Report:

[NO/PRE/QAR20.0006/00](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx PRE 20.0044X**

Page 3 of 3

Date of issue: 2020-06-11

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Remote Optical Watcher (ROW) is autonomous non-contact sensor for detection of oil on water protected with flameproof enclosure type of protection. The system is classified as a class 3B light emission hazard and radiates UV LED light (not within the scope of IEC 60079-28:2015).

The system consists of a pulsed UV LED, receiving telescope, data control and processing electronics. The ROW is enclosed in a metallic enclosure made from stainless steel which consists of tube and two treaded covers (top and bottom flange). Bottom flange includes cemented glass window protected with guard.

The equipment is power supplied through the external cable which is certified as part of the product together with mounted Ex certified cable gland.

Type designation Type: ROW O23**Exd and O45**Exd

Applicable models: O2301E, O2302E, O4500E, O4501E and O4502E.

Electrical data:

Supply voltage

ROW O23**Exd: 10-30 VDC

ROW O45**Exd: 12 VDC

Routine tests:

Each enclosure has to be submitted to routine overpressure test (50.3 bar acc. Cl. 16 of EN 60079-1:2014).

SPECIFIC CONDITIONS OF USE: YES as shown below:

"X" - Equipment must only be placed in areas with low risk of mechanical danger (ref clause 26.4.2 in IEC 60079-0).

"X" - Flameproof joints dimensions specified in the drawings are different than the standard requirements. Min 7 threads must be engaged for all threaded flameproof joints.